

PASSTCERT

QUESTION & ANSWER

Higher Quality
Better Service!

We offer free update service for one year
[HTTP://WWW.PASSTCERT.COM](http://www.passtcert.com)

Exam : BH0-011

**Title : BCS Intermediate Certificate
in EU Code of Conduct for
Data Version: 4.0**

Version : Demo

1. Why has the EU Code of Conduct on Data Centres been developed?

- a. Because data centres are using an increasing amount of power and they need to maximise their efficiency to reduce their impact on the power infrastructure.
- b. Because the power consumption of data centres across Europe as a whole needs to fall to meet agreed CO2 targets.
- c. Because many data centres have outdated designs which focus on perceived reliability at the expense of cost and energy efficiency.
- d. Because the energy consumption of data centres has become a significant business cost.
- e. Because the United States (US) has taken a significant lead in energy conservation and EU-based data centres need a code of conduct to compete in a global marketplace.

- A. a, b, c and d
- B. a, c and d
- C. b and e
- D. e only

Answer: B

2. Which of the following BEST define the aims of the EU Code of Conduct on Data Centres.?

- a. To determine and accelerate the application of energy efficient technologies.
- b. Develop practical voluntary commitments which when implemented improve the energy efficiency of data centres and in so doing minimise the Total Cost of Ownership (TCO).
- c. To develop and promote a set of easily understood metrics to measure the current efficiencies and subsequent improvement.
- d. To encourage the closure of data centres that are less energy efficient.
- e. To ensure that the EU is visibly taking a lead in this important area of energy conservation.

- A. a, b, c and d
- B. d and e
- C. a, b and c
- D. e only

Answer: C

3. A facility's 'IT load', as defined by the Code of Conduct, includes the power drawn by which of the following?

- a. The Power Distribution Units feeding the racks
- b. Servers
- c. Firewalls
- d. Switches
- e. Tape libraries

- A. b, c, d and e
- B. a, d and e
- C. b and c
- D. b, c and d

Answer: A

4. 'Facility load', as defined by the Code of Conduct, includes the power drawn by which of the following?

- a. The UPS.
- b. Lighting.
- c. Air-conditioning units.
- d. Monitors housed in racks.
- e. Tape libraries

A. a, b, and c

B. a and d

C. b and c

D. d, and e

Answer: A

5.The numerical value associated with each Best Practice is shown for the following reason:

A. To allow operators to add up their total score in order that they can be compared with their competitors.

B. To allow the Code of Conduct administrators to properly assess each application.

C. To provide an independent scorecard for data centre owners.

D. To indicate the level of benefit from carrying out a Best Practice.

Answer: D